

**ADDENDUM 1**

**Loan No. and Title** : **Applied For;**  
**Kolkata Environmental Improvement Investment Program (KEIIP) – Project 2**

**Contract No. and Title** : **KEIIP/NCB/TR-2/WS24/2016-17**  
**Dedicated Water Supply Transmission Main from Junction of James Long Sarani to Daspara near existing Pumping Station along James Long Sarani.**

Sl. No	Description and Reference Clause of Bid document	Details of Addendum 1
1	Deadline for submission of On- line Bids	Revised date shall be : 24/08/2016 at 6.00 PM(IST)
2	Deadline for submission of the Original Documents as required in the sub-clause ITB 11 of Section 2 BDS of Bid Document	Revised date shall be : 27/08/2016 at 2.30 PM(IST)
3	Date of opening of Technical bids	Revised date shall be : 27/08/2016 at 3.00 PM(IST)



## ADDENDUM 1

Loan No. and Title:

ADB Loan No.: Applied For ;

Kolkata Environmental Improvement Investment Program (KEIIP) – Project 2

Contract No. and Title

KEIIP/NCB/TR-2/WS24/ 2016-17

Dedicated Water Supply Transmission Main from Junction of James Long Sarani to Daspara near existing Pumping Station along James Long Sarani

Sl. No.	Description and Reference clause of Bid document	Details of Addendum 1
1	Section 6 : Technical Specifications Part A1 : Civil Works – Standard Specification Clause 23.20.10	Insert after the last paragraph the following : ‘ Joints with swelled and plain end for welding shall also be allowed’.
2	Section 6 : Technical Specifications Part A 2 : Civil Works – Particular Standard Specification Clause 6.2 Specific Requirement of Valves	Insert after the last line the following : ‘All valves, fittings, flanges, etc. shall be rated to PN 16’.
3	Section 6 : Technical Specifications Drawing no KEIIP/WS24/GA-ME/09 REV 0	Replace ‘Maximum length of 15 mm MS Pipe (Heavy gauge) – 7 m’ by ‘Maximum length of 15 mm MS Pipe (Heavy gauge) – 6 m’  Replace ‘Gate valve at Pressure gauge point shall be 1 no ‘ by ‘Gate valve at Pressure gauge point shall be 2 nos’



## ADDENDUM 1

Loan No. and Title:

ADB Loan No.: Applied For ;

Kolkata Environmental Improvement Investment Program (KEIIP) – Project 2

Contract No. and Title

KEIIP/NCB/TR-2/WS24/ 2016-17

Dedicated Water Supply Transmission Main from Junction of James Long Sarani to Daspara near existing Pumping Station along James Long Sarani

Sl. No.	Description and Reference clause of Bid document	Details of Addendum 1
	Section 4 : Bill of Quantities Bill no 1 Sl.No.92	Replace '1422 mm OD, 16.0mm thick' By '1422 mm OD, 16.0mm (minimum) thick'.

